CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. Page 1 of 1 7300-0694:241

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Fire Control Instruments, *16 Southwest Park, Westwood MA 02090

Contact: Anthony J. Shalna (781) 471-3000 FAX (781) 471-3099

DESIGN: Model LDM-7100 remote LED annunciator driver module. The unit is intended to be used in

> conjunction with a remote listed electrically compatible fire alarm LED annunciator. Refer to listee's data sheet for detailed product description and operational considerations. System

components:

RATING: Input: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, wiring diagram, applicable codes

and ordinances and in a manner which is acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

Listed as a remote LED annunciator driver for use with separately listed Model 7100 fire APPROVAL:

alarm control unit (CSFM Listing No. 7165-0694:219).

*Rev. 02-05-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 21, 2004 Listing Expires June 30, 2005

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager